

****PLEASE PRINT- ALL FIELDS REQUIRED - ANY MISSING WILL RESULT IN REJECTION OF SUBMITTAL PACKAGE****

THIRD PARTY SANITARY SEWER INSPECTION FORM		DATE:		
Company Inspecting:		Field Engineer:		
Phone #:		Contractor:		
Builder:		Phone #:		
Service Address:		Subdivision:		
PLEASE INCLUDE MEASUREMENTS TO DRAWING		ENGINEER STAMP		
NORTH			Please Mark and Initial Below	
		Meets District Requirements		
		YES	NO	N/A
1	Variances from standard details? If "YES" approval letter from PWSD and all supporting documents shall be attached to inspection.			
2	Provide proper trenching and proper bedding for building sewer. See PWSD details and specifications sheets S1.1 & S1.2.			
3	Provide correct support and backfill for building sewer. See PWSD detail and specifications sheets S1.1 & S1.2.			
4	Minimum grade is 2%. See PWSD detail and specifications sheet S1.2.			
5	Building sewer materials and fittings comply with PWSD standards see detail and specifications sheets S1.1 & S1.2.			
6	Proper joints, connections and fittings for building sewer shall be installed in accordance with PWSD engineering standards. See detail and specifications sheets S1.1 & S1.2.			
7	Building sewer shall have cleanouts, slope and proper drain size in accordance with PWSD specifications. See detail and specifications sheets S1.1 & S1.2.			
8	Sewer service is not located under garage.			
9	Sewer service is marked on the curb face with "X" for sanitary sewer.			
Comments:				

Minimum inspection requirements are deemed to be met, and do not relieve the engineer from any responsibility to conduct such additional inspections as may be necessary to determine that the service line(s) conform to PWSD approved standards/specifications, as well as other applicable codes and regulations accepted for the above referenced property. The inspecting engineer is required to consult PWSD on any unusual condition that may arise. Approved drawings shall be on the job site. Any modifications to accepted plans shall be submitted to PWSD Engineer for review and approval.

I hereby state the at the applicable single-family residential service line was constructed in substantial conformance with PWSD approved standards/specifications for this property, and that all required information and documentation has been provided for the applicable service and address according to PWSD standards/specifications.

INSPECTING ENGINEER: _____ | _____
Signature **Print Name**

Date: ____ / ____ / ____